Stop Flexible Connector Hoses DMH

Checked:

JRM

Approved:

JHB

Date:

04/05/22

Drawn:

T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690

Model No.

EC-3102-SMT8

Item No.

ANSI A117.1 (ADA) UL 1951 ASSE 1070 (TMV)

1:6

Sheet: 1 of 2

Scale:

Travelers Rest. SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

,,,,,,,		··		
ChekPoint*	This Space for Architect/En	gineer Approval		
	Job Name	Date		
ADA Compliant	Model Specified	Quantity		
10 1/4"	Customer/Wholesaler			
[260mm]	Contractor			
2 5/8"	Architect/Engineer			
[66mm]				
	_г —4" x 4 3/8" x 2 3/1	6" Deen		
Solid Cast Brass Spout w/ Polish Chrome Plated Finish	/ [102mm x 111mm	n x 56mm]		
and 2.2 GPM [8.3 L/min] Vandal		Control Module Box Flow Control Setting		
Die Ceet Deek Blete	Switches, AC or D	OC Operated w/ (4) ÅA		
Mount Adjustable Thermostatic Mixing Valve w/ Check Valves	Batteries. Hardwing Terminals on Bac	k		
4"		7/8" 4mm]		
[102mm] 1/2 NPSM x 1/4 NPSM x 1				
Removable				
Strainer	4 3/8"	5 3/8"		
27/16" / 24" [610mm] Sensor Cable	111mm]	[137mm]		
[62mm]	Mounting			
	Surface			
	7/8"			
	[22mm] __			
	Maximum Thickness			
	THICKICSS	VR Aerator Key (Included)		
	─100-240 VAC Adapter	(
	w/ 72" [1830mm] Power	VR Screw L-Key		
	Cord	(Included)		
1/2" NPSM x 1/2				
16" [406mm] Fle Stainless Steel H		Shank Nut Wrench		
(2) 3/8" Compression x	1/2" NPSM	(Included)		
Rough-In Requirement: (2) Ø1" [25mm] Mounting Holes 18" [457mm] Flexible Significant Supply Hoses	tainless Steel			
Product Specifications:	Product Complian	ce:		
Chrome Plated Brass Electronic Faucet: Single Hole Deck Mount Spout w/ 2.2 GPM VR Aerator, 8" Centers Deck Plate, Above Deck Side Mount Adjustable Thermostatic Mixing Valve w/ Check Valves, AC/DC Control Module with Internal Flow Control Setting Switches, 18" Hot & Cold Supply ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) UL 1951				



T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690

9

Model No.

EC-3102-SMT8

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

_			
	ITEM NO.	SALES NO.	DESCRIPTION
	1	B-0199-08	VR 2.2 GPM Aerator, 13/16-27 UN Male w/ Key
	2	015425-45	Vandal Resistant Key
	* 3	019174-45	Sensor Cable Assembly
	4	018251-45	ChekPoint 8" c/c SMT Deck Plate
	5	016297-45	Inlet Hose, Faucet, 1/2" NPSM-F x 1/4" NPSM-F
	6	018249-45	Above Deck TMV Handle
	7	018248-45	Temperature Limit Stop, TMV
	8	EC-SMT	Above Deck Thermostatic Mixing Valve w/ Handle
	9	EC-FILTER	Replacement Filter
	* 10	019944-45	ChekPoint Control Module w/ Filter Tee
	* 11	5EF-0002C	AC Adapter - US Plug
	12	002534-25	Close Nipple, 1/2" NPT
	13	016167-45	Supply Hose, 1/2" NPSM Female Ends
	14	5EF-0005	Supply Hose, 9/16-24 Female x 1/2" NPSM

* For Versions Prior to 2021, Consult with T&S Customer Service

A Maximum of (8) ChekPoint Faucets can be Hardwire Connected and Powered by EC-HARDWIRE ChekPoint Hardwire AĆ Transformer. (Sold Separately)



Flow Control Switches are Located

- Behind Battery Compartment Cover.

 * Switches are Set to DEFAULT Position:
- Auto Time Out = 15 Seconds
- Shut Off Delay = 1 Second
- Auto Flush = OFF
- Metering Mode = OFF

* Available Water Flow Control Selections:

- Auto Time Out: 15 sec. 30 sec. 45 sec. 60 sec. 3 min. 20 min.
- Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec
 Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF

12

13)

- Metering Mode: ON or OFF

Product Specifications:

Drawn:

018543-45

VR Screw L-Key

Chrome Plated Brass Electronic Faucet: Single Hole Deck Mount Spout w/ 2.2 GPM VR Aerator, 8" Centers Deck Plate, Above Deck Side Mount Adjustable Thermostatic Mixing Valve w/ Check Valves, AC/DC Control Module with Internal Flow Control Setting Switches, 18" Hot & Cold Supply Stop Flexible Connector Hoses

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) UL 1951

ASSE 1070 (TMV)

DMH Checked: JRM Approved: JHB Date: 04/05/22 Scale: NTS Sheet: 2 of 2