

# T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088  
Travelers Rest, SC 29690

Model No.

**016647-45BL**

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

This Space for Architect/Engineer Approval

Job Name \_\_\_\_\_ Date \_\_\_\_\_

Model Specified \_\_\_\_\_ Quantity \_\_\_\_\_

Customer/Wholesaler \_\_\_\_\_

Contractor \_\_\_\_\_

Architect/Engineer \_\_\_\_\_



Water Resistant  
Faucet Sensor  
Cable Connection  
(Remove Rubber Cap  
to Connect Cable)

1/2 NPSM Male  
Outlet

Red Cross Decal Identifies  
Medical Control Module

Removable  
Strainer

Mixed Water Elbow  
Fitting with  
Integral Strainer

1/2 NPSM Female 360°  
Swivel Coupling Nut

3 5/8" x 4 3/16" x 2" Deep  
Control Module Box (Gray),  
AC or DC Operated w/ (4)  
AA Batteries. Hardwire  
Capable using Terminals  
on Back

Water Resistant  
Transformer Cable  
Connection Port  
(Remove Rubber Plug  
to Connect Cable)

Battery Storage  
Compartment Access  
Cover

1 1/16"  
[27mm]  
[27mm]

2"  
[51mm]  
[51mm]

2"  
[51mm]  
[51mm]

3 3/8"  
[88]  
[86mm]


ON/OFF Button

## Product Specifications:

ChekPoint Sensor Faucet Medical Control Module  
with Internal Flow Control Setting Switches  
(Gray Module Housing)

## Product Compliance:

UL 1951  
NSF 61 - Section 9  
NSF 372 (Low Lead Content)



# T&S BRASS AND BRONZE WORKS, INC.


2 Saddleback Cove / P.O. Box 1088  
Travelers Rest, SC 29690

Model No.

**016647-45BL**

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com



## \*Available Water Flow Control Selections:

- (6) Auto Time Out Selections - 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min
- (4) Shut Off Delay Selections - 1 sec, 10 sec, 15 sec, 30 sec
- Auto Flush for 30 Seconds After Every 12 Inactive Hours - ON or OFF

## Product Specifications:

ChekPoint Sensor Faucet Medical Control Module  
with Internal Flow Control Setting Switches  
(Gray Module Housing)

## Product Compliance:

UL 1951  
NSF 61 - Section 9  
NSF 372 (Low Lead Content)