



T&S BRASS AND BRONZE WORKS, INC.
 2 Saddleback Cove / P.O. Box 1088
 Travelers Rest, SC 29690

Model No.
132X-V05

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

This Space for Architect/Engineer Approval


Job Name _____ Date _____

Model Specified _____ Quantity _____

Customer/Wholesaler _____

Contractor _____

Architect/Engineer _____



B-0199-06-N05
 VR 0.5 GPM
 Non-Aerated
 Spray Device

Swivel Nut Fits
 All Standard T&S
 Swivel Outlets

8 9/16"
 [217mm]

2 7/8"
 [73mm]

5 9/16"
 [141mm]

Product Specifications:
 2 7/8" Swivel Gooseneck w/ VR 0.5 Non-Aerated Spray Device

Product Compliance:
 ASME A112.18.1 / CSA B125.1
 NSF 61 - Section 9
 NSF 372 (Low Lead Content)